
B-8(1)

"STOP CORONA WIRUS Wash Your Hand/Wear Mask/Maintain Social Distance"



**DELHI JAL BOARD** ( GOVT. OF N.C.T. DELHI ) QUALITY CONTROL LABORATORY, WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water Samples collected "Vandana international Sr. Sec. School" Sec - 10, Phase - 1, Dwarka, New Delhi -110075 Vide Challan No. 137 Dated : - 23.06.2023.

S1:- DJB Supply

S2 :- R. O. water

S.	Particulars	Units	Limit		S1	S2
No.			Acceptable	Permissible		
		PHYSICA	L EXAMINATION	V		
1.	Date of collection				30.06.2023	30.06.2023
2.	Date of Analysis				02.07.2023	02.07.2023
3.	Colour	Hazen	5.0	15	Clear	Clear
4.	Odour		No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	0.94	0.82
6.	PH value		6.5	8.5	7.5	7.6
7.	Electrical Conductivity	μmho			229.5	217.8
8.	Total dissolved solids	mg/l	500	2000	149.18	141.57
	CHE	MICAL EXAN	MINATION		1,3.10	111.07
9.	Phenolphthalein Alkalinity	mg/l			Nil	Nil
10.	Total Alkalinity	mg/l	200	600	67	67
11.	Total Hardness	mg/I	200	600	94	88
12.	Calcium Hardness	mg/I			69	63
13.	Magnesium Hardness	mg/l			25	25
14.	Calcium as Ca	mg/I	75	200	~ 27.6	25.2
15.	Magnesium as Mg	mg/I	30	100	6.0	6.0
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l			NIL	NIL
18.	Nitrate as No <sub>3</sub>	mg/l	45	N.R.	2.6	2.5
19.	Sulphate	mg/l	200	400	34	32
20.	Chloride	mg/I	250	1000	15	15
21.	Dissolved Iron	mg/l	0.3	N.R.	0.06	0.04
22.	Fluoride	mg/l	1	1.5	0.40	0.42
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20	1.0	0.50	NIL
			OGICAL EXAMI	NATION		
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

**REMARKS:** As per tested parameters sample - S1 & S2 can be use for drinking purpose.

Vandana International Sr. Sec. School

Water Analyst **DELHI JAL BOARD** Govt. of N.C.T. Delhi

Quality Control Laboratory

Vandana International Sr. Sec. School (Recognised & Affiliated To C.B.S.E.) (Recognised & Affiliated To C.B.S.E., Sector-10, Dwarka, New Delhi-75 Water Works Nangloi, Delhi-41 Sector-10, Dwarka, New Dethi-75

B-8(2)



## MUNICIPAL CORPORATION OF DELHI

OFFICE OF THE DY. HEALTH OFFICER: NAJAFGARH ZONE ROOM NO.408, 4<sup>TH</sup> FLOOR, ZONAL BUILDING, DHANSA STAND, NAJFGARH, NEW DELHI 110043



No.DHO/NGZ/2023/ 1382

Dated 06 17 2023

Deputy Health Officer

Deputy Healfgath Zone

Najafgarh Zone, MCD

- Name of the School VANDANA INTERNATIONAL SR.SEC. SCHOOL
- 2. School Address SECTOR-10, PHASE I, DWARKA, NEW DELH:-110075
- 3. No. of Shift ONE Timing 08:00 AM TO 02:00 PM
- No. of Students: Boys =1068 Girls=735 Total =1803
- 5. No. of Staffs: Male 13 Female 92 Total = 105

## Details of Accommodations present in School

1.	Floor Space in the Classroom Sufficient/insufficient	SUFFICIENT
2.	The Classrooms are Well Lighted/ ill lighted	WELL LIGHTED
3.	The Classrooms are Well Ventilated/ ill ventilated	WELL VETILATED

- 4. The Classrooms are kept / Not kept Near & Clean: WELL VETILATED

  NEAT AND CLEAN
- 5. The Classrooms/Building requires/ do not required Whitewash etc. NOT REQUIRED
- 6. The Drinking Water is Wholesome/ not wholesome WHOLESOME
- 7. The Latrine arrangement is Sanitary/ insanitary SANITARY FROM HEALTH POINT OF VIEW.

## No. of toilets seats for student

- 1. One latrine-cum-urinal is required for 25 female student, so total is SUFFICIENT
- One latrine for 40 male student is required so total is SUFFICIENT
- Separate Toilet arrangement for staff present: Yes/No YES SEPARATE EXISTS FOR STAFF.
- 4. The Overall facilities: Good/ Adequate/Inadequate V.GOOD FROM HEALTH POINT OF VIEW AND VALID UP TO ONE YEAR FROM ISSUANCE DATE

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

(Remark: Certificate is valid for one year)

Manager

Vandana International Sr. Sec. School (Recognised & Affiliated To C.B.S.E.) Sector-10, Dwarka, New Delhi-75

28,

Vandana International Sr. Sec. Sch. (Recognised & Affiliated To C.B.S.: Sector-10, Dwarka, New Delhi-75